

Electric Grid Reliability & BAAQMD Zero NOx Rules Electric Grid Infrastructure Impacts

C/CAG RMCP Committee Meeting

5/17/2023



Energy+Environmental Economics

Ari Gold-Parker, Associate Director

About Energy & Environmental Economics (E3)



Technical and Strategic Consulting for **the Clean Energy Transition**

~100 consultants across 4 offices with expertise in economics, mathematics, policy, modeling



San Francisco



New York



Boston



Calgary

Our parent company:



Engineering and
energy solutions

Recent E3 Projects


- **BAAQMD Zero NOx Electric Infrastructure Impacts** – E3 supported the air district by analyzing the potential electric infrastructure impacts associated with Zero NOx rule amendments
- **CARB Scoping Plan** – E3 supported the California Air Resource Board in using our PATHWAYS economywide decarbonization model to evaluate long-term scenarios aligned with California's climate targets



Energy+Environmental Economics

Electric Grid Reliability

The electric grid: overview




Congressional research service
<https://sgp.fas.org/crs/misc/R45764.pdf>

What is “electric grid reliability”

- + Reliability = maintaining electricity service for customers, “keeping the lights on”
- + Broadly speaking: two kinds of reliability that describe different types of power outages

	Distribution system reliability	“Bulk system” reliability, a.k.a. “Resource Adequacy”
Type of outage	<ul style="list-style-type: none">• Local outage on part of the distribution system	<ul style="list-style-type: none">• System-wide blackout• Rolling blackouts
Overall outage drivers	<ul style="list-style-type: none">• Weather• Equipment failures or maintenance	<ul style="list-style-type: none">• Not enough generation (and/or transmission) to meet peak load
Direct causes of outages	<ul style="list-style-type: none">• Tree falling on power line• Public Safety Power Shutoff (PSPS) due to fire risk• Planned maintenance projects	<ul style="list-style-type: none">• Inadequate generation to meet peak load• Peak load exceeding forecast• Generator or transmission outage



Distribution system outages

+ Distribution system outages are the **most common outages**


- Only one *bulk system outage* since CA Energy Crisis: August 2020 rolling blackouts
- There were tens or hundreds of thousands of smaller distribution-system outages over this time period

+ Distribution system outages are driven by factors including **weather** and **maintenance**

+ Distribution system outages are generally not driven by **customer load**

- New loads may require distribution system upgrades, leading to costs
- But loads are generally not associated with distribution system reliability

PG&E 2021 – number of distribution outages by cause



https://www.pge.com/en_US/residential/outages/planning-and-preparedness/safety-and-preparedness/grid-reliability/electric-reliability-reports/electric-reliability-reports.page

Bulk system outages

+ Bulk system outages are **much less common**, but can be very disruptive when they occur, e.g.:

- CA rolling blackouts during 2000-2001 energy crisis
- Northeast blackout of 2003
- Texas blackouts during 2021 Winter Storm Uri

2003 Northeast Blackout



+ Bulk system outages are caused by inadequate generation to meet load during peak hours

+ Proximate causes may include **operational errors, high loads, generator outages, or transmission outages**, if these occur during system peak hours

+ Root cause would generally be **issues in system planning, e.g.,** issues associated with:

- Forecasting of load growth
- Modeling of severe weather
- Capturing correlations in generator and/or transmission outages
- Reflecting capacity value of variable and energy-limited resources

No system is perfectly reliable

+ All engineered systems have a tradeoff between cost and risk

- E.g., stormwater systems may be built for a “10-year flood” or a “100-year flood”
 - Building for the 10-year flood is *cheaper* but the system will flood every 10 years
 - Building for the 100-year flood is *more expensive* but the system would only flood every 100 years


+ Bulk power systems are generally designed to a “1-in-10-year” standard

- Empirically, CA’s bulk system has met this standard since the CA energy crisis

+ Distribution outages are more frequent

- PG&E customers experience 1.3 distribution outages per year on average (see figure)

PG&E Average Number of Outages Per Year
SAIFI = System Average Interruption Frequency Index



https://www.pge.com/en_US/residential/outages/planning-and-preparedness/safety-and-preparedness/grid-reliability/electric-reliability-reports/electric-reliability-reports.page

What does this all mean for electrification?

+ New loads may require **new investment**

- Distribution system capacity investments driven by “connected load” or by local peaks
- Transmission and generation capacity investments are driven by system peaks
- Any new loads may need new electric generation resources to serve them

+ New loads **should not directly impact reliability** as long as utilities (e.g., PG&E) and load serving entities (e.g., Peninsula Clean Energy) are planning for them

What does this all mean for electrification?

+ New loads may require **new investment**

- Distribution system capacity investments driven by “connected load” or by local peaks
- Transmission and generation capacity investments are driven by system peaks
- Any new loads may need new electric generation resources to serve them

+ New loads **should not directly impact reliability** as long as utilities (e.g., PG&E) and load serving entities (e.g., Peninsula Clean Energy) are planning for them

+ If **higher loads meant worse reliability...**

- ...then larger electric systems would have worse reliability
- There is no evidence to support this!



+ **Instead, higher loads require more resources to serve them...**

- ...but can be served reliably with good planning



Grid impacts vs. customer impacts

+ E3 study for BAAQMD did not evaluate customer impacts

- Customer costs were considered in a separate part of the BAAQMD rule amendment materials

E3 perspective on customer costs

+ Customer costs of building electrification will be very heterogeneous

+ In addition to equipment and installation costs, some customers may need electric panel and/or service upgrades to support building electrification

- These costs are real and may be expensive!

+ However, these upgrades would likely be needed to support other home upgrades such as electric vehicle charging or air conditioning

- Thus, these costs should not be attributed solely to building electrification

Questions?





Energy+Environmental Economics

BAAQMD Zero NO_x Rules Electric Grid Infrastructure Impacts

Study overview

- + **BAAQMD proposed Zero NOx standards for residential and commercial space and water heaters**
 - These rule amendments were adopted in March 2023
- + **To support an environmental impact review of the proposed rules, E3 analyzed the potential for electric load increases and electric infrastructure impacts**
 - To estimate **conservative (upper-end)** impacts, the study assumed that heat pump devices are used to comply with the zero NOx standards
 - If gas-fired technologies are developed that meet the proposed standards and these devices are adopted by customers, the overall impacts on electric infrastructure would be smaller



**BAY AREA AIR QUALITY
MANAGEMENT DISTRICT**

Key Finding #1

- + **The potential electric grid impacts of the zero NOx standards are highly dependent on the other policies California enacts around building electrification to meet the state's climate goals**
 - In other words, the answer depends on *how much building electrification would occur in the region absent the rule amendments*
- + **E3 developed two different reference scenarios (“counterfactuals”) in which the rule amendments are not implemented**
 - **Low Policy Reference:** assumes no major state policy changes in support of building electrification
 - **High Policy Reference:** assumes major state policy support for building electrification aligned with the California Air Resource Board 2022 Scoping Plan
- + **Relative to the Low Policy Reference:**
 - Zero NOx standards would result in incremental load impacts, capacity impacts, and infrastructure needs by 2050.
- + **Relative to the High Policy Reference:**
 - Zero NOx standards would result in electric grid impacts occurring *earlier than would otherwise be expected*, but there would be *very small net impacts by 2050*.

Key Finding #2

- + **The largest infrastructure impacts would be from increased electric loads and the associated need for zero-carbon generation to meet these loads**
 - Relative to the **Low Policy Reference**, the zero NOx standards could result in 6.2 terawatt-hours per year of additional electric load by 2050, which represents 2.2% of 2020 statewide electric loads.
 - If this load was met by new utility-scale solar, this would require 2180 MW of new solar capacity, with an estimated direct land impact of 19,500 acres
 - New utility-scale solar would likely be sited in the Central Valley, Inland Empire, and/or Mojave Desert, with little to no utility-scale solar development within the Bay Area

- + **While there would also be potential impacts on generation capacity, transmission capacity, and distribution capacity, these capacity-related impacts would be small relative to potential impacts on electric generation**

Summary of potential infrastructure impacts

Table 1: Summary of potential 2050 electric grid impacts of proposed zero NOx standards

	Impact relative to Low Policy Reference	Impact relative to High Policy Reference
Utility-scale solar <i>to serve electric loads</i>	2,180 MW new solar by 2050	70 MW new solar by 2050 <i>+ accelerated build in 2030s & 2040s</i>
4-hour battery storage <i>for generation capacity</i>	680 MW new batteries by 2050	< 10 MW new batteries by 2050 <i>+ accelerated build in 2030s & 2040s</i>
Transmission Capacity	460 MW impact by 2050	< 10 MW impact by 2050 <i>+ accelerated build in 2030s & 2040s</i>
Distribution Capacity	420 MW impact by 2050	< 10 MW impact by 2050 <i>+ accelerated build in 2030s & 2040s</i>

Questions?





Energy+Environmental Economics

Appendix

BAAQMD Electric Infrastructure Impacts

Utility-scale solar

Table 4: Potential utility-scale solar impacts from proposed standards

	2050 impact relative to Low Policy Reference	2050 impact relative to High Policy Reference
Utility-Scale Solar (MW)	2180 MW	70 MW impact by 2050 <i>Accelerated impact in 2030s, 2040s</i>
Cumulative Cost (Real \$2021 Million)	\$1,860	\$390 <i>Due to accelerated build</i>
Land Use (acres)	19,500	700

Battery storage

Table 5: Potential generation capacity impacts from proposed standards

	2050 impact relative to Low Policy Reference	2050 impact relative to High Policy Reference
Generation Capacity (MW)	410 MW	< 10 MW impact by 2050 <i>Accelerated impact in 2030s, 2040s</i>
4-Hour Battery Storage (MW)	680 MW	< 10 MW impact by 2050 <i>Accelerated impact in 2030s, 2040s</i>
Cumulative Cost (Real \$2021 Million)	\$90	\$30 <i>Due to accelerated build</i>
Land Use (acres)	8	< 0.1

Transmission capacity

Table 6: Potential transmission capacity impacts from proposed standards

	2050 impact relative to Low Policy Reference	2050 impact relative to High Policy Reference
Transmission Capacity (MW)	460 MW	< 1 MW impact by 2050 <i>Accelerated impact in 2030s, 2040s</i>
Cumulative Cost (Real \$2021 Million)	\$100	\$25 <i>Due to accelerated build</i>
Associated infrastructure	Costs reflect one transformer upgrade or 10-20% of a 100-mile transmission project	Negligible impact by 2050 <i>Accelerated impact in 2030s, 2040s</i>

Distribution capacity

Table 7: Potential distribution capacity impacts from proposed standards

	2050 impact relative to Low Policy Reference	2050 impact relative to High Policy Reference
Distribution Capacity (MW)	420 MW	< 10 MW impact by 2050 <i>Accelerated impact in 2030s, 2040s</i>
Cumulative Cost (Real \$2021 Million)	\$380	\$100 <i>Due to accelerated build</i>
Estimated Banks (New, by 2050)	6 New Banks	Negligible impact by 2050 <i>Accelerated impact in 2030s, 2040s</i>
Estimated Feeders (New, by 2050)	45 New Feeders	Negligible impact by 2050 <i>Accelerated impact in 2030s, 2040s</i>
Estimated Line Sections (New, by 2050)	10 New Line Section	Negligible impact by 2050 <i>Accelerated impact in 2030s, 2040s</i>
Estimated Banks (Upgrades, by 2050)	31 Bank Upgrades	Negligible impact by 2050 <i>Accelerated impact in 2030s, 2040s</i>
Estimated Feeders (Upgrades, by 2050)	42 Feeder Upgrades	Negligible impact by 2050 <i>Accelerated impact in 2030s, 2040s</i>
Estimated Line Sections (Upgrades, by 2050)	35 Line Section Upgrades	Negligible impact by 2050 <i>Accelerated impact in 2030s, 2040s</i>